

Zoar – Water Report

Inorganic Contaminants:								
	MCLG	MCL	Your Water	Low Range	High Range	Sample Date	Violation	Typical Source
Arsenic (ppb)	NA	50	2.2			4/10/95	No	Erosion of natural deposits. Runoff from orchards. Runoff from glass and electronic production wastes.
Nitrate [measured as Nitrogen] (ppm)	10	10	6.4	0	7.4	10/11/99	No	Runoff from fertilizer use. Leaching from septic tanks, sewage. Erosion of natural deposits.
Alpha emitters (pCi/l)	0	15	7.0	0	7.0	2/15/00	No	Erosion of natural deposits.
Copper (ppm)		1.3	0.03	0	0	8/13/98	No	Erosion of natural deposits. Leaching, Corrosion of household plumbing systems, wood preservatives.